



NAVAJO DIVISION OF TRANSPORTATION

POST OFFICE BOX 4620, WINDOW ROCK, AZ 86515

TEL: 505-371-8300/8301 FAX: 505-371-8399

Addendum #1

Date Addenda Issued: May 8, 2020

Project Name: CN C6193366 - NM 118 CORRIDOR LIGHTING PROJECT FOR 1.63 miles.

Bid #: 20-03-2303LE

Issued by: Navajo Division of Transportation (Navajo DOT) – Department of Roads

- 1) Will Clearing & Grubbing be required, if so, what would be the amount required?
 - a. Minor clearing and grubbing will be necessary depending on how the contractor decides to complete his work (means and methods). It will **not** be a separate pay item. The Contractor shall include the cost to prepare their work area (i.e. clearing and grubbing) in the individual bid items listed.
- 2) Will Seeding be required, if so, what would be the amount required?
 - a. Seeding will be necessary on disturbed areas and the amount will be dependent on how the contractor decides to complete his work. It will **not** be a separate pay item. The Contractor shall include the cost to seed the disturbed work area in the individual bid items listed.
- 3) Will a Field Lab Office be required?
 - a. A Field Lab Office will **not** be required.
- 4) Will a Storm Water Pollution Prevention Plan be required?
 - a. Based on the limited amount of ground disturbance (less than one acre), a SWPPP will **not** be required.
- 5) Will Project Signing be required?
 - a. No
- 6) What type of Street Lighting Cable is to be installed, copper or aluminum?
 - a. Copper

Thank you for your interest:

Marlinda Littleman

Marlinda Littleman, Senior Programs & Projects Specialist

Navajo DOT – Department of Roads

mlittleman@navajodot.org

Received and Acknowledged by:

Name and Title

Company Name

Date

(A copy of the signed addenda shall be included in the Proposal, but it will NOT be counted toward the 10 single-side pages.)